
California Regional Water Quality Control Board, San Diego Region

November 13, 2012

In reply refer to:
251653:rmitchell

Ms. Milica Kaludjerski
Department of Public Works
County of San Diego
5555 Overland Ave., Suite 315
San Diego, CA 92123-1295

**Subject: Review of Monitoring Reports for Order No. 87-108
Rancho Del Campo Water Pollution Control Facility**

Ms. Kaludjerski:

The California Regional Water Quality Control Board, San Diego Region (San Diego Water Board) has reviewed the April-June 2012 and July-September 2012 quarterly monitoring reports submitted by the County of San Diego in accordance with Monitoring and Reporting Program No. 87-108.

The following violations of Section B.1 (Discharge Specifications) of Order No. 87-108 were identified in the submitted reports the 12-month average discharge specification for nitrate, established at 75 milligrams per liter (mg/L), was exceeded for the 12-month period determined in the April-June 2012 and July-September 2012 quarterly monitoring reports with a calculated value of 109.2 and 109.9 mg/L, respectively.

Please be aware these violations subject you to possible further enforcement action by the San Diego Water Board, including administrative enforcement orders requiring you to cease and desist from violations, or to clean up waste and abate existing or threatened conditions of pollution or nuisance; administrative assessment of civil liability in amounts of up to \$5,000 per day per violations;¹ referral to the State Attorney General for injunctive relief; and referral to the District Attorney for criminal prosecution.

The next monitoring report required to be submitted in the October-December 2012 quarterly monitoring report, which is due by January 30, 2013.

¹ Under authority of California Water Code, section 13350.

In the subject line of any response, please include the requested **"In reply refer to"** information located in the heading of this letter. Please contact Mr. Roger Mitchell at (858) 467-2724 or at rmitchell@waterboards.ca.gov if you have any questions on this matter.

Respectfully,



Roger N. Mitchell, P.G.
Engineering Geologist
Cleanup and Land Discharge Branch

RNM:jro:rnmm

Tech Staff Info & Use	
Place ID	251653
Reg. Measure ID	385398
Violation ID	926751, 926752, 926753, 726754